

**Test Report**

**No. GZMR110305856**

**Date: Apr 12, 2011**

**Page 1 of 3**

YUHE GLASS TRADE CO., LTD DONGGUAN CITY  
NO.109, HONGTU ROAD, SCI, & TECH, PARK, NANCHENG ZONE, DONGGUAN CITY, GUANGDONG  
PROVINCE, P.R.C

The following sample(s) was / were submitted and identified on behalf of the client as:

Sample Description : FLOAT TEMPERED GLASS / 800×800×6mm  
SGS Ref. No. : GP110320092-22.17, SDHGR110300405FT  
Test Performed : Selected test(s) as requested by applicant  
Sample Receiving Date : Mar 18, 2011  
Test Performing Date : Mar 18, 2011to Mar 31, 2011  
Test Result(s) : Please refer to the following page(s)

\*\*\*\*\* To be continued\*\*\*\*\*

Signed for and on behalf of  
SGS-CSTC Ltd.

May Huo  
Engineer

This document is issued by the Company under its General Conditions of Service printed overleaf or available on request and accessible at <http://www.sgs.com/termsandconditions.htm>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not constitute a warranty or a guarantee. No party is to be held liable for any loss or damage arising from a transaction from exercising all their rights and obligations under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated, the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only. This document cannot be reproduced, stored in a retrieval system or transmitted in any form or by any means, electronic, mechanical, photocopying, recording or otherwise, without the prior approval of the Company.

**Test Conducted: BS 6206: 1981 & AMD 8693:1995, Impact performance requirements for flat safety glass and safety plastics for use in buildings.**

Glass Size	:	800mm (L) X 800mm (W) X 6.01mm (T)
Test Class	:	Class A
No. of Sample	:	13 Pieces
Glass Type	:	Tempered glass

**1. Toughening Quality Test**

Test Method & Requirements : Strike the test piece 13mm from its longest edge at the midpoint of that edge until breakage occurs, then all particle count determinations shall be completed within 4~5 minutes of the fracture of the test sample. The test piece shall have a minimum particle count of 40 particles in any 50mm x 50mm square.

Test Result : **PASS.** (Particle count: 93particles.)

**2. Impact Test**

Test Method & Requirements :

- Place the test piece in the frame and clamp it appropriately.
- Raise the impactor to a drop height of 305mm and steady it.
- Release the impactor and strikes the test piece.
- Inspect the test piece after impact.
- If test piece fail to comply with the requirements, terminate the procedure. If the test pieces either do not break or else break safely, and it is required to test the material to a higher impact level, increase the drop height to 457mm and repeat the test on four more test pieces of the same material.
- Repeat the test as above steps for a drop height to 1219mm on four more test pieces of the same material.
- The test pieces shall be no breakage or breaks safely.

Test Results	Test Class	Test Results	Rating
	Class C	No breakage	<b>PASS</b>
	Class B	No breakage	<b>PASS</b>
	Class A	Breakage safely	<b>PASS</b>

To be continued...

This document is issued by the Company under its General Conditions of Service printed overleaf or available on request and accessible at <http://www.sgs.com/termsandconditions.htm>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained here on reflects findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not constitute a warranty or a guarantee. No liability shall be accepted for any loss or damage arising from the use of this document. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only. This document cannot be reproduced, stored in a retrieval system or transmitted in any form or by any means, electronic, mechanical, photocopying, recording or otherwise, without the prior approval of the Company.

### 3. Marking


Requirements : All panels shall be marked as follows. These marks shall be permanent and applied before installation in a position to remain visible after installation.

- a) An identifiable name or trademark;
- b) The type of the material;
- c) The number of this British Standard, i.e. BS 6206;
- d) The classification relating to impact test behavior.

Test Result : **PASS.**

Note: The above test was carried out by a SGS laboratory.

### Photo Appendix:



\*\*\*End of Report\*\*\*

This document is issued by the Company under its General Conditions of Service printed overleaf or available on request and accessible at <http://www.sgs.com/termsandconditions.htm>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained here on reflects findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not constitute a warranty or a guarantee in relation to a transaction or a transaction from exercising all their rights and obligations under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated, the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only. This document cannot be reproduced, stored in a retrieval system or transmitted in any form or by any means, electronic, mechanical, photocopying, recording or otherwise, without the prior approval of the Company.